ST HELENA PUBLIC HEALTH LABORATORY
General Hospital, Jamestown, St Helena
Tel: +290 22500 Ext. 2035 Fax: +290 22530
E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0018/26
ISSUE DATE: 02/03/26

UKAS TESTING
4564

Sample type: *Swimming Pool* *Routine Control* *Mains – Chlorinated* *Mains – Untreated* *Other (Specify):*

Sample collection details: *Collected by:* Darren Isaac *Name & Address of Customer:* Connect St Helena, Seals Corner
Collection Date: 23/02/2026 (W019)**;** 25/02/2026 (W020)

Sample receipt details: *Date Received in Lab:* 23/02/2026 (W019)**;** 25/02/2026 (W020)
Testing Date: 23/02/2026 – 26/02/2026 (W019)**;** 25/02/2026-26/02/2026 (W020)

Lab No.	Source/Site	* Macroscopic Appearance	* Cl. Levels (ppm)		Microbiology Results				
					* WM 004 Total Colony Count cfu/1ml		WM 002 WM 005		WM 003
			Free	Total	22ºC/72h	37ºC/48h	Coliforms cfu/100 ml	*E.coli* cfu/100 ml	*Enterococci* cfu/100ml
W019/1	Nr Levelwood Clinic	Clear	1.36	1.44	4	2	Not Detected	Not Detected	Not Detected
W019/2	Contact Tank, Hutt's Gate	Clear	2.47	2.68	49	20	NR	Not Detected	Not Detected
W019/3	Nr Haytown, Ruperts	Clear	1.04	1.16	10	7	Not Detected	Not Detected	Not Detected
W019/4	3 Tanks, HTH	Clear	1.32	1.58	0	0	Not Detected	Not Detected	Not Detected
W020/1	Hutt's Gate Contact Tank	Clear	1.12	1.21	NE	NE	Not Detected	Not Detected	NE

KEY: cfu – colony forming units
NE – Not examined
NR – Not reported

Reported by Food Microbiologist:	Keira Francis	**Signature:**		**Date:**	02/03/2026
Checked by Quality Manager:	Toni Joshua	**Signature:**		**Date:**	02/03/2026
Authorized by Ag. Lab Manager:	Akhona Faas	**Signature:**		**Date:**	02/03/2026

ST HELENA PUBLIC HEALTH LABORATORY
General Hospital, Jamestown, St Helena
Tel: +290 22500 Ext. 2035 Fax: +290 22530
E-mail: microbiology @ sainthelena.gov.sh

WATER MICROBIOLOGY TEST REPORT

REPORT NUMBER: 0018/26
ISSUE DATE: 02/03/26

UKAS TESTING
4564

Notes:
1. Tests marked with * are **NOT** UKAS accredited
2. Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
3. These results relate **ONLY** to the samples as received and tested.
4. Chlorine levels and macroscopic appearance of water samples are provided by the customer on the request form and not by the Laboratory. These can affect the validity of results.
5. This report shall not be reproduced except in full, without written approval of the St Helena Public Health Laboratory.